



48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

電話  
Tel.  
傳真  
Fax. 2824 0578

26 November 2020

Your letters ref. KW08092020-17-2PIPWSD and  
KW03112020-17-2PIPWSD dated 8 September 2020 and 3 November 2020  
respectively refer.

Having considered the test report ref. DP-SUMMARY-2017-2 issued on 2 November 2020 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Benxi Beitai Ductile Cast Iron Pipes Co Ltd

**Country of Origin:** the Mainland of China

**Brand:** K.W. (Koon Wah)

|                          |                                                                                                                |
|--------------------------|----------------------------------------------------------------------------------------------------------------|
| <b>Details of Pipes:</b> | K9 Ductile iron pipes (Push-in joint T-type) with internal cement mortar lining under WRAS approval no.1906558 |
|--------------------------|----------------------------------------------------------------------------------------------------------------|

**Size:** 80mm, 100mm, 150mm, 200mm, 250mm, 300mm,  
350mm, 400mm, 450mm, 500mm, 600mm

**Body Markings:**  BS EN 545 DI K9 size x length



**Expiry Date:** 10 January 2022

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC            ] - with soft copy only