



48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

電話 :
Tel.
傳真 : 2824 0578
Fax.

4 December 2020

Approval of “VILLEROY & BOCH” Bath Mixer (General Acceptance No. C2020117)

Your letters ref. D73A/2020/0807 and D73A/2020/0867 dated 13 October 2020 and 5 November 2020 respectively refer.

Having considered the test report ref. J25538r1 issued on 2 November 2020 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Vicario Armando & Co

Country of Origin: Italy

Brand: Villeroy & Boch

Details of Fitting: 1/2" Single lever bath mixer

Model: TVT10650115161

Body Markings:



Expiry Date: 28 September 2025



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



TVT10650115161