水 務 署
Water Supplies Department

總部 Headquarters
香港灣仔告士打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 *Our ref.* : (4) in WSD 3321/2020 T/J(1360/2020)
來函檔號 *Your ref* :

電話 *Tel.* :
傳真 *Fax.* : 2824 0578

28 December 2020

Approval of "BOLTON" Ductile Iron Fittings
(General Acceptance No. C20201171)

Your letters ref. AL/5158/WSD/GA/RN1 and AL/5158-1/WSD/GA/RN1 dated 20 October 2020 and 26 November 2020 respectively refer.

Having considered the test reports ref. PMA04253 issued on 25 November 2020 by ETS-Testconsult Ltd. and ref. 200730-2222 issued on 14 October 2020 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Foshan Chanshan Foundry Co Ltd

Country of Origin: the Mainland of China

Brand: Bolton

Details of Fittings: Ductile iron fittings with internal cement mortar lining

Description	Size (mm)
Double Flanged Taper	40x32, 50x32, 50x40, 65x32, 65x40, 65x50, 80x32, 80x40, 80x50, 80x65, 100x32, 100x40, 100x50, 100x65, 100x80, 150x50, 150x65, 150x80, 150x100, 150x125, 200x150, 250x200, 300x250

10 years 同心滅癌 caringorganisation

Description	Size (mm)
Double Socket Taper	100x80, 150x80, 150x100, 200x100, 200x150, 250x150, 250x200, 300x150, 300x200, 300x250

Body Markings:

For Double Flanged Taper:
(Bolton) BSEN 545 DI K12 PN16 size x size FZ

For Double Socket Taper:
(Bolton) BSEN 545 DI K12 size x size FZ

Expiry Date: 12 October 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only

Double Socket Taper

Double Flanged Taper