



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2020 T/J(1325/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

29 December 2020

**Approval of “WEDNESBURY” Copper Fittings
(General Acceptance No. C20201183)**

Your letters ref. BK2020-VM-1066 and BK2020-VM-1066(R1) dated 6 October 2020 and 18 November 2020 respectively refer.

Having considered the test report ref. BC-SUMMARY-2020-125 issued on 18 September 2020 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhejiang Hailiang Co Ltd

Country of Origin: the Mainland of China

Brand: Wednesbury

Details of Fittings: Copper fittings with end feed connection ends

Description	Model	Size (mm)
90° Elbow	EF12	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108, 159
45° Elbow	EF21	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108, 159
Reducing 90° Elbow	EF12	22x15
Equal Tee	EF24	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108, 159

Description	Model	Size (mm)
Reducing Tee	EF24P1	22x15x15, 28x22x22
Reducing Tee	EF24P2	22x15x22, 28x22x28
Reducing Tee	EF24B	22x22x28
Reducing Tee	EF24R	22x22x15, 28x28x15, 28x28x22, 35x35x15, 35x35x22, 35x35x28, 42x42x15, 42x42x22, 42x42x28, 42x42x35, 54x54x15, 54x54x22, 54x54x28, 54x54x35, 54x54x42, 66.7x66.7x15, 66.7x66.7x22, 66.7x66.7x28, 66.7x66.7x35, 66.7x66.7x42, 66.7x66.7x54, 76.1x76.1x22, 76.1x76.1x28, 76.1x76.1x35, 76.1x76.1x42, 76.1x76.1x54, 76.1x76.1x66.7, 108x108x22, 108x108x28, 108x108x35, 108x108x42, 108x108x54, 108x108x66.7, 108x108x76.1, 159x159x54, 159x159x66.7, 159x159x76.1, 159x159x108
Coupler	EF01	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108, 159
Reducer	EF01R	22x15, 28x15, 28x22, 35x22, 35x28, 42x22, 42x28, 42x35, 54x22, 54x28, 54x35, 54x42, 66.7x22, 66.7x28, 66.7x35, 66.7x42, 66.7x54, 76.1x28, 76.1x35, 76.1x42, 76.1x54, 76.1x66.7, 108x42, 108x54, 108x66.7, 108x76.1, 159x76.1, 159x108
Reducing Bush	EF06	22x15, 28x15, 28x22, 35x22, 35x28, 42x22, 42x28, 42x35, 54x22, 54x28, 54x35, 54x42, 66.7x28, 66.7x35, 66.7x42, 66.7x54, 76.1x35, 76.1x42, 76.1x54, 76.1x66.7, 108x54, 108x66.7, 108x76.1, 159x76.1, 159x108

Body Markings: W

Expiry Date: 14 September 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only




EF12



EF21



EF12



EF24




EF24P1



EF24P2



EF24B



EF24R



EF01



EF01R



EF06