



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2020 T/J(1499/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

31 December 2020

**Approval of “DECO” Gate Valves
(General Acceptance No. C20201194)**

Your letters ref. SL20201116-1 and SL20201130-1 dated 16 November 2020 and 30 November 2020 respectively refer.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
Deco	DECVC (15mm)	204416PC200224A	25 Nov 2020
Deco	DECVC (22mm)	204416PC200224(1)A	25 Nov 2020
Deco	DECVC (28mm)	204416PC200224(2)A	25 Nov 2020

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yuhuan Jingyilai Valve Co Ltd

Country of Origin: the Mainland of China

Brand: Deco

Details of Fitting: Copper alloy gate valve

Model: DECVC
Size: 15mm, 22mm, 28mm
Body Markings: DECO size in mm PN16
Expiry Date: 23 September 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,


(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



DECVC