



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2020 T/J(1556/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

5 January 2021

**Approval of “WAH HUNG” Hydrant Valves
(General Acceptance No. C20210012FS)**

Your letter dated 8 December 2020 refers.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
Wah Hung	WH005 (80mm)	205153PC200277(1)	8 Dec 2020
Wah Hung	WH005 (100mm)	205153PC200277(2)	8 Dec 2020
Wah Hung	WH006 (80mm)	205153PC200277(3)	8 Dec 2020
Wah Hung	WH007 (80mm)	205153PC200277(4)	8 Dec 2020
Wah Hung	WH008 (80mm)	205153PC200277(5)	8 Dec 2020
Wah Hung	WH008 (80mm)	205153PC200277(6)	8 Dec 2020

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Wah Nan Fire Fighting Equipment Co Ltd

Country of Origin: the Mainland of China

Brand: Wah Hung

- Details of Fittings:**
1. 80mm and 100mm Copper alloy twin inlet with integral non-return valve and drain
Model: WH005
 2. 80mm Copper alloy single outlet hydrant valve
Model: WH006
 3. 80mm Copper alloy single outlet hydrant valve with parity valve
Model: WH007
 4. 80mm Gunmetal hydrant outlet valve with built-in pressure reducing function (2:1) / (3:2)
Model: WH008

Body Markings:

For model WH005 (80mm):

 104 80

For model WH005 (100mm):

 105 100

For model WH006:

 103 80 BS5041/1

For model WH007:

 102 80 BS5041/1

For model WH008 (2:1):

 80 108 2x1

For model WH008 (3:2):

 80 108 3x2

Expiry Date: 1 December 2025

Proviso: The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,


(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



WH005



WH006



WH007



WH008