



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2020 T/J(1470/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

7 January 2021

**Approval of “CHEUNG HING” Float Valves
(General Acceptance No. C20210021)**

Your letters dated 11 November 2020 and 18 December 2020 refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
Cheung Hing	VH80 (80mm)	J25058r2	16 Dec 2020
Cheung Hing	VH100 (100mm)	J25059r2	16 Dec 2020
Cheung Hing	VH150 (150mm)	J25060r2	16 Dec 2020

Having considered the above test reports issued by the Nutek Systems (HK) Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Cheung Hing Manufactory Company Limited

Country of Origin: the Mainland of China

Brand: Cheung Hing

Details of Fitting: Ductile iron equilibrium type ball float valve with epoxy coating under WRAS approval no. 1807559

Model and Size: VH80 – 80mm
 VH100 – 100mm
 VH150 – 150mm

Body Markings: For VH80:
 CH80

 For VH100:
 CH100

 For VH150:
 CH150

Expiry Date: 31 July 2023


This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,


 (CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



VH80 / VH100 / VH150