水 務 署
Water Supplies Department

總部 Headquarters
香港灣仔告士打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 *Our ref.* : (4) in WSD 3321/2020 T/J(1571/2020)
來函檔號 *Your ref* :

電話 *Tel.* :
傳真 *Fax.* : 2824 0578

3 February 2021

Approval of "PETER SMITH" Float Valve
(General Acceptance No. C20210095)

Your letters ref. WSD/AP-02122020-1 and WSD/AP-02122020-1(1) dated 2 December 2020 and 12 January 2021 respectively refer.

Having considered the test report ref. 164853ST161045(6)A issued on 6 January 2021 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	The Peter Smith Valve Company Limited
Country of Origin:	UK
Brand:	Peter Smith
Details of Fitting:	Cast iron equilibrium ball float valve with Rilsan polyamide powder coating under WRAS approval no. 1910523
Model:	Fig.501
Size:	250mm

Body Markings: PSV size in DN PN16

Expiry Date: 31 October 2024

This Authority hereby permits the use of the above fitting in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Fig. 501