水 務 署
**Water Supplies Department**

總部 Headquarters
香港灣仔告士打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 *Our ref.* : ( 3 ) in WSD 3321/2021 T/J(40/2021)
來函檔號 *Your ref.* :

電話 *Tel.* :
傳真 *Fax.* : 2824 0578

4 February 2021

**Approval of "NEOPERL" Flow Controller**
**(General Acceptance No. C20210105)**

Your letter ref. 044-rkre dated 11 December 2020 refers.

Having considered the test report ref. J25781 issued on 10 November 2020 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

| | |
|---|---|
| **Name of Manufacturer:** | Neoperl GmbH |
| **Country of Origin:** | Germany |
| **Brand:** | Neoperl |
| **Details of Fitting:** | Flow controller |
| **Model:** | A5.9042.1 |
| **Body Markings:** | NEOPERL |
| **Expiry Date:** | 3 November 2025 |

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue
ME/MC ] - with soft copy only



A5.9042.1