水 務 署
Water Supplies Department

總部 Headquarters
香港灣仔告士打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 *Our ref.* : (8) in WSD 3321/2020 T/J(1467/2020)
來函檔號 *Your ref.* :

電話 *Tel.* :
傳真 *Fax.* : 2824 0578

9 February 2021

Approval of "KOHLER" Sensor Mixer
(General Acceptance No. C20210120)

Your letter ref. K-77748K-XX dated 10 November 2020 and subsequent submissions received by this department up to 18 January 2021 refer.

Having considered the test report ref. J25655Ar2 issued on 1 December 2020 by Nutek Systems (HK) Ltd. and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Kohler
Country of Origin:	the Mainland of China
Brand:	Kohler
Details of Fitting:	3/8" Deck mounted sensor mixer with 2 nos. of flexible hoses approved by UK's WRAS under ref. 1703069
Model:	K-77748K-XX-YY (where "XX" denote the code of handle, "YY" denote the code of colour finish)
Body Markings:	KOHLER

香港環境卓越大獎 Hong Kong Awards for Environmental Excellence
10 years+ 同心展關懷 caringorganisation

Expiry Date: 31 March 2022

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

> "The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."
>
> "A stop cock or gate valve must be installed at the upstream of the fittings for manual isolation of water supply." AND
>
> "The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



K-77748K-XX-YY