水 務 署
Water Supplies Department

總部 Headquarters
香港灣仔告士打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 *Our ref.* : (8) in WSD 3321/2020 T/J(1456/2020)
來函檔號 *Your ref.* :

電話 *Tel.* :
傳真 *Fax.* : 2824 0578

10 February 2021

Approval of "HYPRO" Sensor Tap
(General Acceptance No. C20210129)

Your letter ref. KLL201106-1301 dated 6 November 2020 and subsequent submissions received by this department up to 29 January 2021 refer.

Having considered the test report ref. RKBA002r1 issued on 7 January 2021 by Ideal Test Consultants Ltd. and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Delichaung Plastic and Electrical Co Ltd
Country of Origin:	the Mainland of China
Brand:	Hypro
Details of Fitting:	1/2" Deck mounted sensor tap with 1 no. of flexible hose approved by UK's WRAS under ref. 2005316
Model:	BH23
Body Markings:	Nil
Expiry Date:	31 May 2025

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

> "A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply." AND
>
> "The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



BH23