水 務 署
Water Supplies Department

總部 Headquarters
香港灣仔告士打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 *Our ref.* : (6) in WSD 3321/2020 T/J(1472/2020)
來函檔號 *Your ref.* :

電話 *Tel.* :
傳真 *Fax.* : 2824 0578

10 February 2021

Approval of "KITZ" Strainers
(General Acceptance No. C20210132)

Your letters ref. KHC2020-025, KHC2020-034 and KHC2021-004 dated 10 November 2020, 30 December 2020 and 20 January 2021 respectively refer.

Having considered the test report ref. BC-SUMMARY-2020-136 issued on 18 January 2021 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Kitz Corporation
Country of Origin:	the Mainland of China
Brand:	Kitz
Details of Fitting:	Cast iron Y-strainer with epoxy powder coating under WRAS approval no. 2008501
Model:	EN16FCYEP
Size:	65mm, 80mm, 100mm, 125mm, 150mm, 200mm, 250mm, 300mm

Body Markings: KITZ (DN) PN16 CI ➡

Expiry Date: 31 August 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



EN16FCYEP