



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2020 T/J(1506/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

10 February 2021

**Approval of "KING LION" UPVC Pipes
(General Acceptance No. C20210133F)**

Your letter ref. HK/KLSD/LL20/072 dated 18 November 2020 and subsequent submissions received by this department up to 26 January 2020 refer.

Brand	Size	Material Tech Test Report Ref.	Issuance Date
King Lion	15mm	01126W000018B	15 Jan 2021
King Lion	20mm	01126W000018-1B	15 Jan 2021
King Lion	25mm	01126W000018-2B	15 Jan 2021
King Lion	32mm	01126W000018-3B	15 Jan 2021
King Lion	40mm	01126W000018-4B	15 Jan 2021
King Lion	50mm	01126W000018-5B	15 Jan 2021
King Lion	65mm	01126W000018-6B	15 Jan 2021
King Lion	75mm	01126W000018-7B	15 Jan 2021
King Lion	100mm	01126W000018-8B	15 Jan 2021
King Lion	150mm	01126W000018-9B	15 Jan 2021

Having considered the above test reports issued by the Material Tech Company Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: King Lion PVC Pipes & Fittings MFY Ltd

Country of Origin: the Mainland of China



Brand: King Lion

Details of Pipes: uPVC pipes in grey colour (Class E)

Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm, 65mm, 75mm, 100mm, 150mm

Body Markings:  KING LION UPVC PIPE
BS3505 CLASS "E" size in mm

Expiry Date: 16 September 2025

Proviso: As the pipes have not been tested for use in contact with water intended for human consumption, the pipes can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above pipes in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in flushing water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,


(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only