



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2021 T/J(191/2021)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

23 February 2021

**Approval of “SEAH (PSP)” Galvanized Steel Pipes  
(General Acceptance No. C20210139FS)**

Your letter ref. BK2021-VM-1073 dated 13 January 2021 refers.

Having considered the test reports ref. BC-SUMMARY-2020-144 and BC-SUMMARY-2020-145 both issued on 23 October 2020 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** SeAH Steel Corporation

**Country of Origin:** South Korea

**Brand:** SeAH (PSP)

**Details of Pipes:** Galvanized steel pipe (class medium & class heavy)

**Size:** 25mm, 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 150mm

**Body Markings:**

For class medium:

SčAH SeAH Steel EN10255:2004 SERIES MEDIUM  
 W Size x Length PSP MADE IN KOREA BUN KEE  
 PRODUCTION CODE

For class heavy:

SčAH SeAH Steel EN10255:2004 SERIES HEAVY  
 W Size x Length PSP MADE IN KOREA BUN KEE  
 PRODUCTION CODE

**Expiry Date:**

13 October 2025

**Proviso:** The pipes can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipes in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
 ME/MC ] - with soft copy only