



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2021 T/J(218/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

23 February 2021

**Approval of "BOWLING" Galvanized Steel Pipes
(General Acceptance No. C20210140FS)**

Your letter ref. BK2020-VM-1071 dated 22 December 2020 refers.

Having considered the test reports ref. BC-SUMMARY-2020-147 and BC-SUMMARY-2020-148 both issued on 2 November 2020 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jinan Mech Piping Technology Co Ltd

Country of Origin: the Mainland of China

Brand: Bowling

Details of Pipes: Galvanized steel pipe (class medium & class heavy)

Size: 25mm, 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 150mm

Body Markings:

For class medium:

Bowling EN10255:2004 SERIES MEDIUM W
Size x Length PRODUCTION CODE

For class heavy:

Bowling EN10255:2004 SERIES HEAVY W
Size x Length PRODUCTION CODE**Expiry Date:**

28 October 2025

Proviso: The pipes can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipes in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only