



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號

Our ref.

來函檔號

Your ref.

(2) in WSD 3321/2021 T/J(211/2021)

電話

Tel

傳真

Fax

2824 0578

4 March 2021

**Approval of “TATA DUCTURA” Ductile Iron Pipes
(General Acceptance No. C20210200)**

Your letter ref. BK2021-VM-1075 dated 21 January 2021 refers.

Having considered the test report ref. BC-SUMMARY-2020-162 issued on 26 November 2020 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tata Metaliks DI Pipes Limited

Country of Origin: India

Brand: Tata Ductura

Details of Pipes: K12 Ductile iron pipes (Push-in flexible joint) with internal cement mortar lining under WRAS approval no. 2009545

Size: 80mm, 100mm, 150mm, 200mm

Body Markings: TATA DUCTURA BSEN545 size x length
K12 production code

Expiry Date: 30 September 2025

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only