



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2.) in WSD 3321/2021 T/J(368/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

16 March 2021

**Approval of "YUE HING" Hydrant Valves
(General Acceptance No. C20210276FS)**

Your letter ref. WSD/AP-26022021-1 dated 26 February 2021 refers.

Brand	Model No. (Ratio)	Fugro Test Report Ref.	Issuance Date
Yue Hing	Fig.803 (2:1)	210845PC210037(6)	25 Feb 2021
Yue Hing	Fig.803 (3:1)	210845PC210037(7)	25 Feb 2021
Yue Hing	Fig.803 (3:2)	210845PC210037(8)	25 Feb 2021
Yue Hing	Fig.803 (4:3)	210845PC210037(9)	25 Feb 2021
Yue Hing	Fig.803 (5:4)	210845PC210037(10)	25 Feb 2021

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yue Hing Machine Factory Ltd

Country of Origin: the Mainland of China

Brand: Yue Hing

Details of Fitting: 80mm Copper alloy self contained pressure reducing fire hydrant valve (2:1) / (3:1) / (3:2) / (4:3) / (5:4)



Model: Fig.803
Body Markings: 
Expiry Date: 17 February 2026

Proviso: The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Fig.803