



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (7) in WSD 3321/2020 T/J(1385/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

31 March 2021

**Approval of "FQR" Angle Valve
(General Acceptance No. C20210337)**

Your letter ref. SL20201021-1 dated 21 October 2020 and subsequent submissions received by this department up to 11 March 2021 refer.

Having considered the test report ref. 204709PC200231(1)C issued on 1 March 2021 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: FQR Frattini SRL
Country of Origin: Italy
Brand: FQR
Details of Fitting: 1/2" x 1/2" Copper alloy angle valve
Model: 122SD-44
Body Markings: FQR PA 354
Expiry Date: 25 February 2026

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,




(Roger WONG)

for Director of Water Supplies

Encl.

c.c.	WSD 3321/1/82	] - without catalogue
	ME/MC	] - with soft copy only



122SD-44