



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(402/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

1 April 2021

**Approval of “ASAHI” UPVC Pipes
(General Acceptance No. C20210346)**

Your letters ref. BK2021-VM-1078 and BK2021-VM-1078(R1) dated 5 March 2021 and 19 March 2021 respectively refer.

Having considered the test reports ref. BC-SUMMARY-2021-024 issued on 18 March 2021 and ref. 210106-2775 & 210209-2330 both issued on 9 February 2021 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Asahi Yukizai Corporation

Country of Origin: Japan

Brand: Asahi

Details of Pipes: uPVC pipes in grey colour

Size: 16mm, 20mm, 25mm, 30mm, 40mm, 50mm, 65mm, 75mm, 100mm, 150mm, 200mm, 250mm, 300mm

Body Markings:

For size 16mm to 150mm:

JIS K6742  **AVEニルパイプ** VP size ∞ PVC-U

For size 200mm to 300mm:

JIS K6741  **AVEニルパイプ** VP size ∞ PVC-U**Expiry Date:** 27 January 2026

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only