



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2021 T/J(374/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

16 April 2021

**Approval of "CHEUNG KAY" Galvanized Steel Pipes
(General Acceptance No. C20210390)**

Your letter dated 1 March 2021 refers.

Having considered the test reports ref. PMA10785 and AGA01384 issued on 22 February 2021 and 10 November 2020 by ETS-Testconsult Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangzhou Cheung Kay Metal Products Manufacturing Co Ltd

Country of Origin: the Mainland of China

Brand: Cheung Kay

Details of Pipe: Galvanized steel pipes (class medium) with internal polyethylene lined coating

Size: 20mm, 25mm, 40mm, 50mm, 80mm, 100mm, 150mm

Body Markings:  祥基鋼塑管 CHEUNG KAY POLYETHYLENE LINED STEEL PIPE BS EN 10255 size x length
Production date

Expiry Date:

9 November 2025

This Authority hereby permits the use of the above pipes in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only