



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(260/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

27 April 2021

**Approval of "GAMMAP" PE Pipes
(General Acceptance No. C20210442)**

Your letters ref. KW01022021-21-1PIPWSD and
KW13042021-21-1PIPWSD dated 1 February 2021 and 14 April 2021 respectively
refer.

Having considered the test reports ref. DP-SUMMARY-2021-1 and
201120-2428 issued on 14 January 2021 and 9 April 2021 by Castco Testing Centre
Limited, this Authority accepts that the pipes described below comply with, and their
use when correctly installed does not contravene, the Waterworks Ordinance and
Regulations.

Name of Manufacturer: Guangzhou Fenye Pipe Industrial Co Ltd

Country of Origin: the Mainland of China

Brand: Gammap

Details of Pipes: PE pipes in black colour (PE100, SDR11)

Size: 25mm, 32mm, 40mm, 50mm, 63mm, 90mm, 125mm,
180mm, 250mm, 315mm

Body Markings:

water PE100 (DN) x (wall thickness)
SDR11 PN16 EN12201

Expiry Date:

17 October 2025

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only