



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(262/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

3 May 2021

**Approval of "GAMMAP" PE Fittings
(General Acceptance No. C20210469)**

Your letters ref. KW01022021-21-3FITWSD and KW13042021-21-3FITWSD dated 1 February 2021 and 14 April 2021 respectively refer.

Having considered the test reports ref. DP-SUMMARY-2021-3 and 201120-2428 issued on 8 April 2021 and 9 April 2021 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangzhou Fenye Pipe Industrial Co Ltd

Country of Origin: the Mainland of China

Brand: Gammap

Details of Fittings: PE fittings in black colour (PE100, SDR11)

Description	Size (mm)
Electrofusion 90° Elbow	32, 40, 50, 63, 90, 125, 315
Electrofusion 45° Elbow	40, 50, 63, 90, 315
Electrofusion Tee	32, 40, 50, 63, 90, 125, 315

Description	Size (mm)
Electrofusion Reducing Coupling	40x32, 50x32, 50x40, 63x40, 63x50, 90x63, 315x250
Electrofusion Reducing Tee	40x40x32, 50x50x32, 50x50x40, 63x63x40, 63x63x50, 90x90x63, 315x315x250

Body Markings:

For Elbow:



size x angle EN12201 PE100 PN16 SDR11

For Tee, Reducing Tee and Reducing Coupling:



size x size EN12201 PE100 PN16 SDR11

Expiry Date:

22 December 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only




Electrofusion 45° Elbow



Electrofusion 90° Elbow



Electrofusion Tee



Electrofusion
Reducing Tee



Electrofusion Reducing
Coupling