



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(513/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

5 May 2021

**Approval of "PAM" Ductile Iron Pipe
(General Acceptance No. C20210483)**

Your letters ref. GWL/21/0329 and GWL/21/0414 dated 29 March 2021 and 14 April 2021 respectively refer.

Having considered the test report ref. BC-SUMMARY-2021-031 issued on 22 February 2021 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Saint-Gobain PAM France

Country of Origin: France

Brand: PAM

Details of Pipe: K12 Ductile iron socket and spigot pipe with internal cement lining under WRAS approval no. 1802557

Size: 80mm

Body Markings: **PAM** CLASSIC (DN) Zn200 CLASS E
K12 / C100 EN545 (Production Code)



Expiry Date: 28 February 2023

This Authority hereby permits the use of the above pipe in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fail to meet that of the approved sample or if the pipe is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only