



48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

電話 :
Tel.
傳真 : 2824 0578
Fax.

18 May 2021

Approval of “TOZEN” Flexible Joints (General Acceptance No. C20210523F)

Your letter ref. TLL/M838/20 dated 6 November 2020 and subsequent submissions received by this department up to 28 April 2021 refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
Tozen	Twinflex screwed type (15mm)	J25612Ar3	26 Apr 2021
Tozen	Twinflex screwed type (20mm)	J25612Br3	26 Apr 2021
Tozen	Twinflex screwed type (25mm)	J25612Cr3	26 Apr 2021
Tozen	Twinflex screwed type (32mm)	J25612Dr3	26 Apr 2021
Tozen	Twinflex screwed type (40mm)	J25612Er3	26 Apr 2021
Tozen	Twinflex screwed type (50mm)	J25612Fr3	26 Apr 2021

Having considered the above test reports issued by the Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.



Name of Manufacturer: Tozen Corporation

Country of Origin: the Mainland of China

Brand: Tozen

Details of Fitting: Twin sphere rubber flexible joint

Model: Twinflex screwed type

Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm

Body Markings: For size 15mm to 25mm:
TOZEN TWINFLEX 15·20·25

For size 32mm and 40mm:
TOZEN TWINLFEX 32(1¼) 40(1½)

For size 50mm:
TOZEN TWINFLEX 50(2)

Expiry Date: 26 October 2025

Proviso: The fittings can only be used in flushing water plumbing systems and fresh water fire services systems.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Twinflex screwed type