



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(719/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

8 June 2021

**Approval of "TYT" Gate Valves
(General Acceptance No. C20210597)**

Your letters both ref. WSD-06-05-2021 dated 6 May 2021 and 21 May 2021 refer.

Brand	Model No. (Size)	Ideal Test Report Ref.	Issuance Date
TYT	TYTG-2SS (15mm)	RWTC001Ar1	21 May 2021
TYT	TYTG-2SS (20mm)	RWTC001Br1	21 May 2021
TYT	TYTG-2SS (25mm)	RWTC001Cr1	21 May 2021
TYT	TYTG-2SS (32mm)	RWTC001Dr1	21 May 2021
TYT	TYTG-2SS (40mm)	RWTC001Er1	21 May 2021
TYT	TYTG-2SS (50mm)	RWTC001Fr1	21 May 2021
TYT	TYTG-2SS (65mm)	RWTC001Gr1	21 May 2021
TYT	TYTG-2SS (80mm)	RWTC001Hr1	21 May 2021

Having considered the above test reports issued by the Ideal Test Consultants Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: M/s Goodyear Valves Works Corp

Country of Origin: Taiwan, China

Brand: TYT

Details of Fittings: Stainless steel gate valve

Model: TYTG-2SS

Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm, 65mm, 80mm

Body Markings: T.Y.T. size in inch 300 CF8M

Expiry Date: 23 April 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



TYTG-2SS