



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(421/2021)

Our ref.

來函檔號 :

Your ref.

電話 :

Tel.

傳真 :

Fax.

2824 0578

9 July 2021

**Approval of "PLAST" PE Fittings
(General Acceptance No. C20210731)**

Your letters dated 25 January 2021 and 4 June 2021 refer.

Brand	Type of Fittings	ETS Test Report Ref.	Issuance Date
Plast	PE Fittings - Tee	PMA10739	5 Feb 2021
Plast	PE Fittings - Bend	PMA10740	6 Feb 2021
Plast	PE Fittings - Reducer	PMA10741A	3 Jun 2021
Plast	PE Fittings - Bend	PMA12342	21 May 2021

Having considered the above test reports and ref. AGA10656 issued on 17 May 2021 by ETS-Testconsult Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Plastitalia SPA

Country of Origin: Italy

Brand: Plast

Details of Fittings: PE fittings in blue colour (PE100, SDR11)

Description	Size (mm)
Electrofusion Elbow 45°	32, 50
Electrofusion Elbow 90°	32, 50
Electrofusion Equal Tee	32, 50, 63
Electrofusion Reducer	50x32, 90x50, 250x180
Spigot Reducer	50x32, 63x32, 63x50, 125x63, 125x90, 180x125, 250x180, 315x250

Body Markings:

For Elbow (50mm):

PLAST size x angle PE100 SDR11

For Elbow 45° (32mm):

PLAST size x angle PE100 PN WATER 16 SDR11

For Elbow 90° (32mm):

PLAST size PE100 SDR11 WATER EN 12201

For Tee and Reducer:

PLAST size PE100 SDR11

Expiry Date:

11 January 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Electrofusion fitting
Elbow 45°



Electrofusion
fitting Elbow 90°



Electrofusion Equal
Tee 90°



Electrofusion Reducer



Spigot Reducer