



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(808/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

16 July 2021

**Approval of “TRM CHINA” Ductile Iron Fittings
(General Acceptance No. C20210766)**

Your letters dated 18 May 2021 and 8 June 2021 refer.

Having considered the test report ref. PMA12060A issued on 7 June 2021 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Shangdong Jianhua Valve Making Co Ltd

Country of Origin: the Mainland of China

Brand: TRM China

Details of Fittings: Ductile iron fittings with cement mortar lining under WRAS approval no. 2010531

Description	Size (mm)
Double Socket 90° Bend	80, 100, 150, 200, 250, 300
Double Socket 45° Bend	80, 100, 150, 200, 250, 300
Double Flanged 90° Bend	80, 100, 150, 200, 250, 300
Double Flanged 45° Bend	80, 100, 150, 200, 250, 300

Body Markings:

For Double Socket Bends:

TRM China BSEN 545:2010 HS DN size x angle

For Double Flanged Bends:

TRM China BSEN 545:2010 BSEN 1092

HS PN16 DN size x angle

Expiry Date:

31 October 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Double Socket 45° Bend



Double Socket 90° Bend



Double Flanged 45° Bend



Double Flanged 90° Bend