



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/2021 T/J(365/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

27 July 2021

**Approval of “YD” Galvanized Steel Pipes
(General Acceptance No. C20210810FS)**

Your letter dated 24 February 2021 and subsequent submissions received by this department up to 7 June 2021 refer.

Brand	Size	Fugro Test Report Ref.	Issuance Date
YD	25mm	205730PC200416A	14 Apr 2021
YD	65mm	202300PC200106	19 Aug 2020
YD	200mm	202300PC200140B	14 May 2021

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangzhou Nanyue Steel Tube Co Ltd

Country of Origin: the Mainland of China

Brand: YD

Details of Pipes: Galvanized steel pipes (class medium)



Size: 25mm, 65mm, 200mm

Body Markings: For size 25mm and 65mm:
YD EN10255/BS1387 Series MEDIUM
W size x length

For size 200mm:
YD EN10217-1/BS3601 DN size x length

Expiry Date: 8 July 2025

Proviso: The pipes can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipes in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only