



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (10) in WSD 3321/2021 T/J(601/2021)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

27 July 2021

**Approval of "BELLINI" Basin Mixers  
(General Acceptance No. C20210813)**

Your letter ref. FY210419C dated 19 April 2021 and subsequent submissions received by this department up to 25 June 2021 refer.

Having considered the test report ref. REIA027r1 issued on 17 May 2021 by Ideal Test Consultants Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Kaiping City Shanghua Sanitary Ware Co Ltd

**Country of Origin:** the Mainland of China

**Brand:** Bellini

**Details of Fittings:** 3/8" Single lever basin mixer

**Model:** BXX-6889 and BXX-6889H  
(where "XX" denote the code of handles)

**Body Markings:** 

**Expiry Date:** 11 April 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless otherwise specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)  
for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
            ME/MC            ] - with soft copy only



**BXX-6889**



**BXX-6889H**