



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(811/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

30 July 2021

**Approval of “XINXING (P.A.)” Ductile Iron Fittings
(General Acceptance No. C20210827)**

Your letters dated 21 May 2021 and 18 June 2021 refer.

Having considered the test reports ref. PMA01866A and PMA01867A both issued on 21 July 2020 and ref. PMA01868 issued on 12 June 2020 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Shandong Jianhua Valve Making Co Ltd

Country of Origin: the Mainland of China

Brand: Xinxing (P.A.)

Details of Fittings: Ductile iron fittings with internal epoxy powder coating under WRAS approval no. 2104535

Description	Size (mm)
Double Socket 90° Bend	80, 100, 250, 450, 600
Double Socket 45° Bend	80, 100, 200, 250, 350, 400
Double Socket 22.5° Bend	80, 100, 200, 250, 350, 400

Description	Size (mm)
Double Socket 11.25° Bend	80, 100, 200, 250, 400
Double Flanged 90° Bend	80, 200
Double Flanged 45° Bend	80, 100, 150, 200, 300, 400
Double Flanged 22.5° Bend	100, 150
Double Flanged 11.25° Bend	100, 150, 200
All Socket Tee	80x80x80, 100x100x80, 100x100x100, 150x150x80, 150x150x100, 150x150x150, 200x200x80, 200x200x100, 200x200x150, 200x200x200, 300x300x250, 350x350x200, 350x350x300, 400x400x200, 400x400x300
Double Socket Tee with Flanged Branch	100x100x80, 100x100x100, 150x150x80, 150x150x100, 150x150x150, 200x200x80, 200x200x100, 200x200x150, 300x300x250, 400x400x200
All Flanged Tee	80x80x80, 100x100x80, 100x100x100, 150x150x80, 150x150x100, 150x150x150, 200x200x80, 200x200x150, 300x300x100, 400x400x100, 400x400x200, 400x400x300
Double Socket Taper	100x80, 150x80, 150x100, 200x100, 200x150, 250x150, 250x200, 350x200, 400x300, 450x300
Double Flanged Taper	100x80, 150x100, 200x100, 200x150, 250x150, 300x200, 350x250, 400x200

Body Markings:

For Double Socket Bend:

P A BS EN 545 DI K12 size x angle

For Double Flanged Bend:

P A BS EN 545 DI K12 PN16 size x angle

For All Socket Tee:

P A BS EN 545 DI K12 size x size

For Double Socket Tee with Flanged Branch and All Flanged Tee:

P A BS EN 545 DI K12 PN16 size x size

For Double Socket Taper:

P A BS EN 545 DI K12 size x size

For Double Flanged Taper:

P A BS EN 545 DI K12 PN16 size x size

Expiry Date:

5 June 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Double Socket 90° Bend



Double Socket 45° Bend



Double Socket 22.5° Bend



Double Socket 11.25° Bend



Double Flange 45° Bend



Double Flange 90° Bend



Double Flange 22.5° Bend



Double Flange 11.25° Bend



Double Socket Taper



Double Flange Taper



Double Socket Tee with Flanged Branch



All Socket Tee



All Flange Tee