



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2021 T/J(887/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

2 August 2021

**Approval of "PHW" Ductile Iron Fittings
(General Acceptance No. C20210835)**

Your letters ref. WSDGA/PHWDIF/210528, WSDGA/PHWDIF/210623 and WSDGA/PHWDIF/210705 dated 1 June 2021, 23 June 2021 and 5 July 2021 respectively refer.

Having considered the test reports ref. PMA12347B and AGA90388 issued on 29 June 2021 and 11 October 2019 by ETS-Testconsult Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Foshan Chanshan Foundry Co Ltd
Country of Origin: the Mainland of China
Brand: PHW
Details of Fittings: Ductile iron fittings with cement mortar lining

Description	Size (mm)
Double Flanged 11.25° Bend	80, 100, 150, 200, 250, 300
Double Flanged 22.5° Bend	80, 100, 150, 200

Body Markings: PHW (manufacture date) BS EN545 DI K12
PN16 size x angle FZ

Expiry Date: 9 October 2024

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Double Flanged 11.25° Bend



Double Flanged 22.5° Bend