



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(972/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

4 August 2021

**Approval of "TOYO" Gate Valves
(General Acceptance No. C20210853)**

Your letters ref. GWL/21/0621 and GWL/21/0708 dated 21 June 2021 and 8 July 2021 respectively refer.

Having considered the test report ref. BC-SUMMARY-2021-087 issued on 4 June 2021 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kitz (Thailand) Ltd

Country of Origin: Thailand

Brand: Toyo

Details of Fitting: Copper alloy gate valve

Model: Fig.207

Size: 15mm, 22mm, 28mm, 35mm, 42mm, 54mm

Body Markings: RED WHITE TOYO (Inch) 125S 200 WOG

Expiry Date: 25 May 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Fig. 207