



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/2021 T/J(621/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

11 August 2021

**Approval of “ANCHOR” UPVC Pipes
(General Acceptance No. C20210891F)**

Your letter dated 23 April 2021 and subsequent submissions received by this department up to 20 July 2021 refer.

Brand	Size	Fugro Test Report Ref.	Issuance Date
Anchor	16mm	164406ST160940B	13 July 2021
Anchor	20mm	164406ST160940(1)B	13 July 2021
Anchor	25mm	164406ST160940(2)B	13 July 2021
Anchor	30mm	164406ST160940(3)B	13 July 2021
Anchor	40mm	164406ST160940(4)B	13 July 2021
Anchor	50mm	164406ST160940(5)B	13 July 2021
Anchor	65mm	164406ST160940(6)B	13 July 2021
Anchor	75mm	164406ST160940(7)B	13 July 2021
Anchor	100mm	164406ST160940(8)B	13 July 2021
Anchor	150mm	164406ST160940(9)B	13 July 2021
Anchor	200mm	164406ST160940(10)B	13 July 2021

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhongshan Universal Enterprise Ltd

Country of Origin: the Mainland of China

Brand: Anchor

Details of Pipes: uPVC pipes in grey colour (Class E)

Size: 16mm, 20mm, 25mm, 30mm, 40mm, 50mm, 65mm, 75mm, 100mm, 150mm, 200mm

Body Markings: 通过 ISO 9001 体系认证 
WA size JIS K6742 W. P. pressure rating

Expiry Date: 10 October 2021

Proviso: As the pipes have not been tested for use in contact with water intended for human consumption, the pipes can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above pipes in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in flushing water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only