



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2021 T/J(975/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

20 August 2021

**Approval of “EGEPLAST” PE Pipes
(General Acceptance No. C20210932)**

Your letter dated 22 June 2021 and subsequent submissions received by this department up to 27 July 2021 refer.

Having considered the test reports ref. DP-SUMMARY-2017-9 issued on 23 July 2021 by Castco Testing Centre Limited and ref. AGA11001 issued on 15 June 2021 by ETS-Testconsult Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Egeplast Werner Strumann GmbH & Co KG
Country of Origin: Germany
Brand: Egeplast
Details of Pipes: PE pipes in blue colour (PE100, SDR11)
Size: 32mm, 50mm, 63mm, 90mm, 125mm, 180mm, 250mm, 315mm

Body Markings:

For 32mm:

egeplast 9010 PE100 PE-HD 003 TW SDR11 PN16 32 x 3.0 DIN/BS EN 12201 W
GRAD B DIN 8074/75 II DVGW BO 0099 300617 1846 Extr. 29

For 50mm:

egeplast 9010 PE100 PE-HD 003 TW SDR11 PN16 50 x 4.6 DIN/BS EN 12201 W
GRAD B DIN 8074/76 III DVGW BO 0099 290617 1340 Extr. 29

For 63mm:

egeplast 9010 PE100 PE-HD 003 TW SDR11 PN16 63 x 5.8 DIN/BS EN 12201 W
GRAD B DIN 8074/75 II DVGW BO 0099 290617 0916

For 90mm:

egeplast 9010 PE100 PE-HD 003 TW SDR11 PN16 90 x 8.2 DIN/BS EN 12201 W
GRAD B DIN 8074/75 1086 I DVGW BO 0100 5 270617

For 125mm:

egeplast 9010 PE100 PE-HD 003 TW SDR11 PN16 125 x 11.4 DIN/BS EN 12201 W
GRAD B DIN 8074/75 16056 I DVGW BO 0100 280617

For 180mm:

egeplast 9010 PE100 PE-HD 003 TW SDR11 PN16 180 x 16.4 DIN/BS EN 12201 W
GRAD B DIN 8074/75 III DVGW BO 0100 020617 1792 Extr. 5

For 250mm:

egeplast 9010 PE100 PE-HD 003 TW SDR11 PN16 250 x 22.7 DIN/BS EN 12201 W
GRAD B DIN 8074/75 II DVGW BO 0101 250617 1688 Extr. 5

For 315mm:

egeplast 9010 PE100 PE-HD 003 TW SDR11 PN16 315 x 28.6 DIN/BS EN 12201 W
GRAD B DIN 8074/75 III DVGW BO 0101 180517 0610 Extr. 29

Expiry Date: 23 September 2022

This Authority hereby permits the use of the above pipes in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG
at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only