



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1076/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

23 August 2021

**Approval of "DUVALCO" Gate Valves
(General Acceptance No. C20210942)**

Your letters dated 14 July 2021 and 2 August 2021 refer.

Having considered the test report ref. PFA80047 issued on 2 February 2018 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Duvalco Valves (Wuxi) Co Ltd

Country of Origin: the Mainland of China

Brand: Duvalco

Details of Fittings: Ductile iron resilient seated gate valve with epoxy powder coating under WRAS approval no. 2104535

Model and Size:
17056A080BCC-001 – 80mm
17056A100BCC-001 – 100mm
17056A150BCC-001 – 150mm
17056A200BCC-001 – 200mm
17056A250BCC-001 – 250mm
17056A300BCC-001 – 300mm

Body Markings: DUVALCO size in DN BS5163
RES SG 500-7 PN16 2017

Expiry Date: 22 January 2023

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.


Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



17056A080BCC-001 / 17056A100BCC-001 /
17056A150BCC-001 / 17056A200BCC-001 /
17056A250BCC-001 / 17056A300BCC-001 /