



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1116/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

25 August 2021

**Approval of "MASON" Flexible Joints
(General Acceptance No. C20210955F)**

Your letters ref. L01105 and L01105 (v2) dated 20 July 2021 and 2 August 2021 respectively refer.

Having considered the test report ref. 206484PC210075 issued on 13 July 2021 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Mason Industries Inc
Country of Origin: Thailand
Brand: Mason
Details of Fittings: Twin sphere rubber flexible joint
Model: SUPER-FLEX MFTNC
Size: 50mm, 80mm, 100mm, 150mm

Body Markings: M I MASON SUPER FLEX size in inch
 SUPER MFTNC size in mm
 ERE 250PSI 170°F 165PSI 250°F

Expiry Date: 12 May 2026

Proviso: The fittings can only be used in flushing water plumbing systems and fresh water fire services systems.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
 for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



SUPER-FLEX MFTNC