



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(919/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

30 August 2021

**Approval of "ARTISENSE" Sensor Taps
(General Acceptance No. C20210989)**

Your letters ref. L21-091 and L21-091R1 dated 3 June 2021 and 28 July 2021 respectively refer.

Having considered the test report ref. RGTC031r4 issued on 23 July 2021 by Ideal Test Consultants Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: HDSafe Technologies Co Ltd

Country of Origin: the Mainland of China

Brand: Artisense

Details of Fittings: 1/2" Deck mounted sensor tap with 1 no. of flexible hose approved by UK's WRAS under ref. 2104328

Model: ART.001.0002.001.XX and ART.001.0002.002.XX
(where "XX" denote the codes of finishes)

Body Markings: ARTISENSE

Expiry Date: 24 September 2025



This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"A stop cock or gate valve must be installed at the upstream of the fittings for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless otherwise specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



ART.001.0002.001.XX /
ART.001.0002.002.XX