



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1187/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

31 August 2021

**Approval of "ARON" UPVC Pipes
(General Acceptance No. C20211011)**

Your letters ref. HM20210726E-1 and HM20210821E-1 dated 26 July 2021 and 17 August 2021 respectively refer.

Having considered the test reports ref. J26611A-Jr1 and J26771r1 both issued on 17 August 2021 by Nutek Systems (HK) Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Aron Kasei Co Ltd

Country of Origin: Japan

Brand: Aron

Details of Pipes: uPVC pipes in grey colour (Class E)

Size: 16mm, 20mm, 25mm, 30mm, 40mm, 50mm, 65mm, 75mm, 100mm, 150mm

Body Markings:

Size (mm)	Body Markings
16	C)K(⊗ JW JW0406003 JIS K 6742 ヲアロソルイヲ VP 16 N 2009 01 6 スイドウ ○ ∞ PVC-U
20	C)K(⊗ JW JW0406003 JIS K 6742 ヲアロソルイヲ VP 20 N 2009 01 6 スイドウ ○ ∞ PVC-U
25	C)K(⊗ JW JW0406003 JIS K 6742 ヲアロソルイヲ VP 25 N 2010 01 8 スイドウ ○ ∞ PVC-U
30	C)K(⊗ JW JW0406003 JIS K 6742 ヲアロソルイヲ VP 30 N 2010 01 6 スイドウ ○ ∞ PVC-U
40	C)K(⊗ JW JW0406003 JIS K 6742 ヲアロソルイヲ VP 40 N 1804 17 6 スイドウ ○ ∞ PVC-U
50	C)K(⊗ JW JW0406003 JIS K 6742 ヲアロソルイヲ VP 50 N 1903 27 6 スイドウ ○ ∞ PVC-U
65	⊗ JET JIS K 6741 JE0312002 ヲアロソルイヲ VP 65 N 2001 05 7 ∞ PVC-U
75	C)K(⊗ JW JW0406003 JIS K 6742 ヲアロソルイヲ VP 75 N 2003 06 6 スイドウ ○ ∞ PVC-U
100	C)K(⊗ JW JW0406003 JIS K 6742 ヲアロソルイヲ VP 100 N 2003 06 6 スイドウ ○ ∞ PVC-U
150	C)K(⊗ JW JW0406003 JIS K 6742 ヲアロソルイヲ VP 150 N 1905 25 6 スイドウ ○ ∞ PVC-U

Expiry Date:

8 July 2026

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only