



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1202/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

9 September 2021

**Approval of “HQB” Galvanized Steel Pipe
(General Acceptance No. C20211015FS)**

Your letters dated 30 July 2021 and 23 August 2021 refer.

Having considered the test report ref. RSFE005 issued on 6 May 2021 by Ideal Test Consultants Ltd., this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangdong Shanshi Iron and Steel Co Ltd

Country of Origin: the Mainland of China

Brand: HQB

Details of Pipe: Galvanized steel pipe (class medium)

Size: 125mm

Body Markings: HQB® BS1387 / BSEN10255 W
size x thickness x length (M)

Expiry Date: 21 April 2026

Proviso: The pipe can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipe in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fresh water fire service systems.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only