



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1247/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

13 September 2021

**Approval of "SHOWA" Check Valves
(General Acceptance No. C20211029)**

Your letters ref. PDD/OSL/210810/T2 and PDD/OSL/210823/T4 dated 10 August 2021 and 23 August 2021 respectively refer.

Having considered the test reports ref. BC-SUMMARY-2021-110 issued on 30 June 2021 & ref. 210401-2329 issued on 15 July 2021 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Showa Valve Co Ltd
Country of Origin: the Mainland of China
Brand: Showa
Details of Fittings: Cast iron silent check valve with epoxy coating
Model: Fig.40R
Size: 50mm, 65mm, 80mm, 100mm, 125mm, 150mm, 200mm, 250mm

Body Markings: "Size" → SHOWA "Production Code"

Expiry Date: 24 June 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Fig.40R