



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/2021 T/J(761/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

15 September 2021

**Approval of "HOLLY" Copper Fittings
(General Acceptance No. C20211046)**

Your letter dated 14 May 2021 and subsequent submissions received by this department up to 26 August 2021 refer.

Having considered the test reports ref. 210511PC210025(4)B issued on 28 July 2021 and ref. 210511PC210025C, 210511PC210025(1)C, 210511PC210025(2)C & 210511PC210025(3)C issued on 24 August 2021 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Ningbo Hengsheng Pipe Fitting Co Ltd

Country of Origin: the Mainland of China

Brand: Holly

Details of Fittings: Copper fittings with end feed capillary

Description	Model	Size (mm)
90° Elbow	H-E01	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108, 159
45° Elbow	H-E02	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108, 159
Reducing Elbow	H-E03	22x15

Description	Model	Size (mm)
Tee	H-T01	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108
Reducing Tee	H-T02	15x15x22, 22x15x15, 22x15x22, 22x22x15, 22x22x28, 28x28x15, 28x28x22, 35x35x15, 35x35x22, 35x35x28, 42x42x15, 42x42x22, 42x42x28, 42x42x35, 54x54x15, 54x54x22, 54x54x28, 54x54x35, 54x54x42, 66.7x66.7x28, 66.7x66.7x35, 66.7x66.7x42, 66.7x66.7x54, 76.1x76.1x28, 76.1x76.1x35, 76.1x76.1x42, 76.1x76.1x54, 76.1x76.1x66.7, 108x108x42, 108x108x54, 108x108x66.7, 108x108x76.1
Straight Coupling	H-C01	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108, 159
Reducer	H-C02	22x15, 28x15, 28x22, 35x15, 35x22, 35x28, 42x15, 42x22, 42x28, 42x35, 54x15, 54x22, 54x28, 54x35, 54x42, 66.7x28, 66.7x35, 66.7x42, 66.7x54, 76.1x28, 76.1x35, 76.1x42, 76.1x54, 76.1x66.7, 108x35, 108x42, 108x54, 108x66.7, 108x76.1
End Cap	H-C03	15, 22, 28, 35, 42, 54, 76.1

Body Markings: EN 1254-1  HOLLY size in mm

Expiry Date: 30 May 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



90° Elbow




45° Elbow



Reducing Elbow



End Cap



Straight Coupling



Tee



Reducer



Reducing Tee