



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/2021 T/J(1048/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

19 October 2021

**Approval of “KONTI HIDROPLAST” PE Pipes
(General Acceptance No. C20211146)**

Your letter dated 7 July 2021 and subsequent submissions received by this department up to 16 September 2021 refer.

Having considered the test reports ref. PMA12605A and AGA10823A issued on 24 August 2021 and 21 July 2021 by ETS-Testconsult Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Konti Hidroplast

Country of Origin: Macedonia

Brand: Konti Hidroplast

Details of Pipes: PE pipes in blue colour (PE100, SDR11)

Size: 63mm, 90mm, 125mm, 180mm, 250mm, 315mm

Body Markings: KONTI HIDROPLAST PORTABLE WATER DVGW
DVGW's Approval No. TW DIN EN12201-2
PN16 PE100RC TYPE 2 PAS1075 SDR11
DN/OD x Wall thickness GRAD B Batch No.

Expiry Date: 28 April 2026

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only