



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1292/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

21 October 2021

**Approval of "P.A." Ductile Iron Pipes
(General Acceptance No. C20211164)**

Your letters dated 20 August 2021 and 10 September 2021 refer.

Having considered the test report ref. PMA00711 issued on 10 March 2020 by ETS-Testconsult Limited and WRAS certificates, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Xinxing Ductile Iron Pipes Co Ltd

Country of Origin: the Mainland of China

Brand: P.A.

Details of Pipes: K12 Ductile iron socket and spigot pipes with internal epoxy seal coat (under WRAS approval no. 2106514) for cement mortar lining (under WRAS approval no. 1802547)

Size: 80mm, 100mm, 150mm, 200mm, 300mm, 400mm, 450mm

Body Markings: XINXING PIPES P.A. BSEN 545 K12 class
DIP T TYPE size x length Zn200

Expiry Date: 28 February 2023

This Authority hereby permits the use of the above pipes in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only