



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1226/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

1 November 2021

**Approval of “SEAH (PSP)” Galvanized Steel Pipes
(General Acceptance No. C20211217FS)**

Your letters ref. BK2021-VM-1100 and BK2021-VM-1100(R1) dated 3 August 2021 and 4 October 2021 respectively refer.

Having considered the test report ref. BC-SUMMARY-2021-123 issued on 14 September 2021 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: SeAH Steel Corporation

Country of Origin: South Korea

Brand: SeAH (PSP)

Details of Pipes: Galvanized steel pipes

Size: 200mm x 5.6mm, 200mm x 6.3mm,
250mm x 6.3mm, 300mm x 6.3mm

Body Markings: SëAH SeAH STEEL EW EN10217-1:2002 P265TR1
C2 size x thickness x length PSP MADE IN KOREA
BUN KEE Production code

Expiry Date: 7 September 2026

Proviso: The pipes can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipes in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only