



48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

電話
Tel.
傳真
Fax

2 November 2021

**Approval of "TOTO" Sensor Tap
(General Acceptance No. C20211221)**

Your letter ref. L-TT-8579 dated 30 August 2021 refers.

Having considered the test reports ref. 207006PC200466(30) and 201726EN201352 issued on 18 August 2021 and 4 March 2021 by Fugro Technical Services Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	TOTO (Shanghai) Co Ltd
Country of Origin:	the Mainland of China
Brand:	TOTO
Details of Fitting:	1/2" Wall mounted sensor tap with 1 no. of flexible hose
Model:	TLE24004H + TLE03501H
Body Markings:	TOTO
Expiry Date:	30 July 2025



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,




(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



TLE24004H + TLE03501H