



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1484/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

9 November 2021

**Approval of "S.H." Ball Valves
(General Acceptance No. C20211253F)**

Your letters ref. HM20210924E-1 and HM20211020E-1 dated 24 September 2021 and 20 October 2021 respectively refer.

Having considered the test report ref. RSLB035r1 issued on 15 October 2021 by Ideal Test Consultants Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Shie Yu Machine Parts Industrial Co Ltd

Country of Origin: Taiwan, China

Brand: S.H.

Details of Fitting: uPVC ball valve in gray colour

Model and Size: CC100-016G - ½"
CC100-020G - ¾"
CC100-025G - 1"
CC100-032G - 1¼"
CC100-038G - 1½"
CC100-050G - 2"

Body Markings:



Expiry Date: 13 September 2026

Proviso: As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,

A handwritten signature in black ink, appearing to be 'Roger Wong', written in a cursive style.

(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



CC100-016G / CC100-020G / CC100-025G /
CC100-032G / CC100-038G / CC100-050G