



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1435/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

26 November 2021

**Approval of “MASTER BELLOWS, CHINA” Expansion Joints
(General Acceptance No. C20211319)**

Your letters dated 1 September 2021 and 4 November 2021 refer.

Having considered the test report ref. 204391PC200483A issued on 3 November 2021 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Hangzhou Ehase-Flex Co Ltd

Country of Origin: the Mainland of China

Brand: Master Bellows, China

Details of Fitting: Stainless steel expansion joint

Model: UNSST(PN16)

Size: 40mm, 50mm

Body Markings: Master Bellows, China UNSST size length
Bellow Threads Tube : SUS304 PN16
Lateral Movement : 50mm+/-25mm ➡

Expiry Date: 10 June 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.


Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



UNSST(PN16)