



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1625/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

30 November 2021

**Approval of “ASAHI” Ball Valves
(General Acceptance No. C20211340F)**

Your letter ref. BK2021-VM-1105 dated 2 November 2021 and subsequent clarification by email on 18 November 2021 refer.

Having considered the test reports ref. BC-SUMMARY-2021-093 and BC-SUMMARY-2021-133 issued on 7 June 2021 and 21 July 2021 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Asahi Yukizai Corporation

Country of Origin: Japan

Brand: Asahi

Details of Fitting:

1. uPVC Grey compact ball valve type 27 - socket ends
Model: V7BLVUESJ
Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm
2. uPVC Grey compact ball valve type 27 - thread ends
Model: V7BLVUENJ
Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm

3. uPVC White compact ball valve type 27 - socket ends
Model: V7BLVUESB
Size: 15mm
4. uPVC White compact ball valve type 27 - socket ends
Model: V7BLVUES4
Size: 20mm

Body Markings:



ASAHI

Expiry Date:

12 May 2026

Proviso: As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



V7BLVUESJ



V7BLVUESB /
V7BLVUES4



V7BLVUENJ