



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (10) in WSD 3321/2021 T/J(1307/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

2 December 2021

**Approval of "WIIK" PE Pipe
(General Acceptance No. C20211345)**

Your letter dated 18 August 2021 and subsequent submissions received by this department up to 12 November 2021 refer.

Having considered the test reports ref. PMA14541 and AGA01161 issued on 19 August 2021 and 28 September 2020 by ETS-Testconsult Limited, this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Wiik Public Company Limited

Country of Origin: Thailand

Brand: WIIK

Details of Pipe: PE pipe in blue colour (PE100, SDR11)

Size: 250mm

Body Markings: BS EN12201 WIIK PE100 PIPE 250 x 22.7
SDR11 PN16 Batch No.

Expiry Date: 22 September 2025

This Authority hereby permits the use of the above pipe in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fail to meet that of the approved sample or if the pipe is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only