



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/2021 T/J(1196/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

16 December 2021

**Approval of "TAI-FLEX" Settlement Joints
(General Acceptance No. C20211401)**

Your letter dated 2 August 2021 and subsequent submissions received by this department up to 26 November 2021 refer.

Having considered the test reports ref. 201357PC200394B and 196764EN203148A issued on 2 November 2021 and 24 November 2021 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Taisei Kiko Co Ltd

Country of Origin: Japan

Brand: Tai-Flex

Details of Fitting: Ductile iron settlement joint with epoxy coating

Model: TF80

Size: 50mm, 80mm, 100mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm, 500mm, 600mm

Body Markings:

For size 50mm:

TAI-FLEX TF80 TAISEIKIKO CO LTD
 MADE IN JAPAN BSEN 1092-2 PN16
 ト水 D 20 Product code

For others:

TAI-FLEX TF80 TAISEIKIKO CO LTD
 MADE IN JAPAN ト水 D 20 BSEN 1092-2
 PN16 size PN16 BS4504 Product code

Expiry Date:

19 February 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
 for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



TF80